



**TÜV NORD CERT**

**Certificate about the testing of the  
degrees of protection provided by enclosures**

Testing laboratory  
Safety of technical systems

**Client:** Rolec  
Gehäuse-Systeme GmbH  
Kreuzbreite 2

D – 31737 Rinteln

**Devices under  
test:** Enclosure series technoBox  
Serie:  
TBA 060 until TBA 162

**Tested in accordance to:** EN 60529: 2000 Degrees of protection provided by enclosures (IP Code)  
Requirements towards system of protection IP 66 and IP 67  
Enclosures of category I;  
Dust test with negative pressure

**Conductor of test:** A. Schmidt

**Order number:** 8000307813

**Period of test:** from 25.08.2003 until 08.09.2003

**Result:** The enclosure series technoBox fulfils the requirements of the degrees of protection IP 66 and IP 67

TÜV NORD CERT GmbH & Co. KG  
Am TÜV 1  
D – 30519 Hannover

Hannover, 08.09.2003

K. H. Schwedt  
Head of testing laboratory  
Safety of technical systems